

AltaLink transmission line – 1043L (formerly 904L): Potential hazard warning – spacer damper failure

As part of our ongoing commitment to safety, AltaLink will be increasing the frequency of its inspections along the 1043L transmission line, formerly called 904L. AltaLink is increasing inspections along 1043L line to monitor the condition of a piece of equipment called a spacer damper. The Métis Nation of Alberta (MNA) was engaged in 2009 regarding the 1043L (904L) Transmission Line Rebuild development. The MNA's members may be conducting Traditional Land Use activities where the 1043L line will require more frequent inspections. We are asking the MNA to communicate to their members the potential safety issue related to the spacer dampers.

A spacer damper connects two or more wires at intervals between transmission towers to reduce movement in adverse weather conditions by preventing the wires from contacting and damaging each other. Spacer dampers are attached to the wires with clamps and secured by bolts. The picture below is an example of a spacer damper installed on a transmission line.



AltaLink is increasing inspections because installed spacer dampers of this type have failed on AltaLink transmission lines. Clamp bolts on the failed spacer damper did not remain secure and the clamp released from the wire, causing a portion of the spacer damper to fall to the ground. The picture below is an example of a spacer damper in a failed condition.









AltaLink will be inspecting spacer dampers on an ongoing basis and will address any issues as required. Inspection activities on Crown lands may include low-level helicopter flight inspections, ground level inspections and crews accessing the line from service trucks.

There is a possibility that a spacer damper, or parts of a spacer damper, could fall to the ground from the overhead transmission wires. AltaLink asks that MNA members who have access to the right-of-way, please avoid walking along or under the right-of-way at the following locations where the spacer dampers have been installed on Crown lands for 1043L (also see the corresponding Strip Mosaic [SM] maps enclosed):

- NW-12-52-3-W5 (SM4)
- NW-7-52-2-W5 (SM4)
- NW-8-52-2-W5 (SM5)

- SW-1-52-2-W5 (SM8)
- NE-4-52-25-W4 (SM19)
- NW-3-52-25-W4 (SM19)

If circumstances are such that you must cross and/or walk along the right-of-way, please avoid crossing under and walking in areas below the spacer dampers.

If the MNA members believe they have found pieces of spacer dampers on the ground, or notice a spacer damper that appears to be in the failed position outlined and shown above, please contact AltaLink at 1-877-380-0303 or landowner.advocate@altalink.ca and AltaLink will conduct further inspection and investigation.

Please do not pick up or move the pieces because seeing them in their original location will allow AltaLink to more easily identify the line section from which the spacer damper fell.







AltaLink apologizes for any inconvenience this may cause and appreciates your help in this communication and letting us know if your members see anything unusual regarding the spacer dampers. Thank you for your cooperation in advance as we work to maintain the safety of the transmission system.

Sincerely,

Kris Gladue


Manager, Aboriginal Relations


AltaLink


O: 780-948-4035 | C: 780-717-1639













Municipal or County Boundary





Photography dated: 2013 Source: Valtus Imagery Services 40cm Colour Ortho Photogra Although there is no reason to believe that there are any errors associated with the data used to generate this product or in the product itself, users of these data are advised that errors in the data may be present.

0.25

0.5 Kilometres

0.25 Miles

Affected Line Segments: Land Existing Transmission Line

Municipal or County Boundary

 Wellsite Pipeline

- Road

ALTALINK

